

# VOC Content Test Certificate

Monday April 4<sup>th</sup>, 2011

Manufacturer: Construction Chemicals Pty Ltd (135-147 Cormack Rd, Wingfield, SA)

Sample Description: Monoflex

Date Tested: March 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168

Test Data:

|   |  |
|---|--|
| <b>Specification</b><br><br><b>Green Building Council of Australia<br/>Green Star Office Design V3 IEQ-13</b> | <b>Monoflex</b>  |
| Ceramic tile adhesive<br><br>65 grams per Litre as VOC content material                                       | <b>5.0 grams per Litre as VOC<br/>content per material</b> |



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F1103-17