

VOC Content Test Certificate

Monday April 11th, 2011

Manufacturer: Construction Chemicals Pty Ltd (135-147 Cormack Rd, Wingfield, SA)

Sample Description: SuperPrime

Date Tested: March 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	SuperPrime
Sub-floor adhesive 50 grams per Litre as VOC content material	18 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1103-17