

# VOC Content Test Certificate

Wednesday, 24<sup>th</sup> August 2016

Manufacturer: Construction Chemicals Pty Ltd (49-57 Davis Street, Wingfield, SA, 5013).

Sample Description: Ultima

Date Tested: August 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 “Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings”

Test Data:

<p><b>Specification</b></p> <p><b>Green Building Council of Australia Green Star Design &amp; As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B</b></p>	<p><b>ULTIMA</b></p>
<p>General purpose adhesives and sealants: 50 grams per Litre as VOC content per material</p>	<p><b>16 gram per Litre as VOC content per material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

CV160810