

VOC Content Test Certificate

Wednesday, 24th August 2016

Manufacturer: Construction Chemicals Pty Ltd (49-57 Davis Street, Wingfield, SA, 5013).

Sample Description: Featureflor

Date Tested: August 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 “Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings”

Test Data:

<p>Specification</p> <p>Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B</p>	<p>FEATUREFLOR</p>
<p>General purpose adhesives and sealants: 50 grams per Litre as VOC content per material</p>	<p>6 gram per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV160810