

ACOUSTIC TESTING SUMMARY



Dribond CONSTRUCTION
CHEMICALS

www.constructionchemicals.com.au

ACOUSTIC TESTING SUMMARY

Date	State	Acoustic Engineer	Site Location	Underlay Type	Adhesive	Floor Covering	Slab Thickness	Cavity	Bare Slab	LnTw rating	Difference
9/26/02	NSW	Acoustic Logics	Unknown	5 mm Acoustiflor	Acoustibond	10 mm Tile	200 mm	Nil		53 FIC	
8/17/02	QLD	Palmer Acoustcis	Aria Apartments	5 mm Acoustiflor	Acoustibond	10 mm Tile	220 mm	65 mm	67 LnTw	51 LnTw	16 points
3/14/03	QLD	Ron Rumble Eng	Cutters Landing Original	3 mm Acoustiflor	Acoustibond	10 mm Tile	170 mm	Nil	72 LnTw	58 LnTw	14 points
3/14/03	QLD	Ron Rumble Eng	Cutters Landing Original	5 mm Acoustiflor	Acoustibond	10 mm Tile	170 mm	Nil	72 LnTw	57 LnTw	15 points
3/14/03	QLD	Ron Rumble Eng	Cutters Landing Original	5 mm Acoustiflor	Ultrathane	10 mm Tile	170 mm	Nil	72 LnTw	55 LnTw	17 points
3/14/03	QLD	Ron Rumble Eng	Cutters Landing Original	5 mm Acoustiflor	Ultima Adhesive	10 mm Tile	170 mm	Nil	72 LnTw	59 LnTw	13 points
3/14/03	QLD	Ron Rumble Eng	Cutters Landing Original		Acoustibond	10 mm Tile	170 mm	Nil	72 LnTw	62 LnTw	10 points
3/14/03	QLD	Ron Rumble Eng	Cutters Landing Original		Ultrathane Adhesive	10 mm Tile	170 mm	Nil	72 LnTw	53 LnTw	19 points
1/14/05	QLD	Palmer Acoustics	Riparian Plaza	5 mm Acoustiflor	Acoustibond	8 mm Tile	250 mm	65 mm	66 LnTw	56 LnTw	10 points
3/24/05	QLD	Palmer Acoustics	Ephraim Island	5 mm Acoustiflor	Acoustibond	10 mm Tile	200 mm	65 mm	67LnTw	51 LnTw	16 points
4/3/06	QLD	Palmer Acoustics	Verve on Broadbeach	5 mm Acoustiflor	Acoustibond	10 mm Tile	220 mm	170 cavity	66 LnTw	58 LnTw	8 points
11/7/06	QLD	Ron Rumble Eng	Allisee Apartments	5 mm Acoustiflor	Acoustibond	9 mm Tile	200 mm	250 mm + Insul	69 LnTw	48 LnTw	21 points
12/22/06	QLD	Ron Rumble	Allisee Apartments	5 mm Acoustiflor	Acoustibond	9 mm Tile	200 mm	250 cavity	70 LnTw	50 LnTw	20 points
7/3/07	QLD	Palmer Acoustics	Norman Reach Bethany	6 mm Acoustiflor	Acoustibond	8 mm Tile	240 mm	117 mm	66 LnTw	51 LnTw	15 points
7/3/07	QLD	Palmer Acoustics	Norman Reach Bethany	6 mm Acoustiflor	Gripflex	8 mm Tile	240 mm	117 mm	66 LnTw	55 LnTw	11 points
7/3/07	QLD	Palmer Acoustics	Norman Reach Bethany	6 mm Acoustiflor	Ultrathane	Timber	240 mm	117 mm	66 LnTw	45 LnTw	21 points
8/12/10	QLD	Aecom Acoustic Eng	Grocon	9 mm Acoustiflor	Acoustibond	10 mm Tile	200 mm	75 mm	64 LnTw	50 LnTw	14 points
5/20/13	QLD	Acoustic Works	Carmel by the Sea	6 mm Acoustiflor	Acoustibond	9 mm Tile	180 mm	Nil	71 LnTw	62 LnTw	9 points
5/20/13	QLD	Acoustic Works	Carmel by the Sea		Acoustibond	9 mm Tile	180 mm	Nil	71 LnTw	67 LnTw	4 points
9/7/14	QLD	Sound Matters	Broadway On Ann		Acoustibond	9 mm Tile	200 mm	150 cavity	67 LnTw	63 LnTw	4 points
11/28/14	QLD	Palmer Acoustcis	Cutters Landing - Schumilo	9 mm Acoustiflor	Acoustibond	10 mm Tile	170 mm	Nil	70 LnTw	50 LnTw	20 points
3/8/16	QLD	Alpha Acoustics	Parrearra Apts		Acoustibond	10 mm Tile	200 mm	Nil	69 LnTw+Ci	55 LnTw+Ci	10 points
9/6/16	QLD	Alpha Acoustics	Breeze Apartments	6 mm Acoustiflor	Monoflex	10 mm Tile	200 mm	50 mm	69 LnTw	58 LnTw	11 points
2/7/17	QLD	Alpha Acoustics	Deception Bay	6 mm Acoustiflor	Acoustibond	10 mm Tile	180 mm	Nil	71 LnTw	61 LnTw	10 points
2/7/17	QLD	Alpha Acoustics	Deception Bay	9 mm Acoustiflor	Acoustibond	10 mm Tile	180 mm	Nil	71 LnTw	60 LnTw	11 points
9/6/17	QLD	Alpha Acoustics	96 Main Street Montville	6 mm Acoustiflor	Monoflex	8 mm Tile	150 mm	280 mm + Insul	71 LnTw	59 LnTw	12 points
7/11/18	QLD	Alpha Acoustics	34 Picnic Point Maroochydhore		Acoustibond	10 mm Tile	200 mm	Nil	74 LnTw	63 LnTw	11 points
7/11/18	QLD	Alpha Acoustics	34 Picnic Point Maroochydhore	6 mm Acoustiflor	Acoustibond	10 mm Tile	200 mm	Nil	74 LnTw	59 LnTw	15 points
7/11/18	QLD	Alpha Acoustics	34 Picnic Point Maroochydhore	6 mm Acoustiflor	Monoflex	10 mm Tile	200 mm	Nil	74 LnTw	59 LnTw	15 points
3/20/19	QLD	Dedicated Acoustics	Noosa Springs Hutchinsons	6 mm Acoustiflor	Acoustibond	10 mm Tile	200 mm	100 mm	69 LnTw	50 LnTw	19 points
3/20/19	QLD	Dedicated Acoustics	Noosa Springs Hutchinsons	9 mm Acoustiflor	Acoustibond	10 mm Tile	200 mm	100 mm	69 LnTw	51 LnTw	18 points
3/20/19	QLD	Dedicated Acoustics	Noosa Springs Hutchinsons	6 mm Acoustiflor	Monoflex	10 mm Tile	200 mm	100 mm	69 LnTw	58 LnTw	11 points
6/6/19	QLD	Dedicated Acoustics	External Deck over Habitable	6 mm Acoustiflor	Monoflex	10 mm Tile	200 mm	100 mm	65 LnTw	48 LnTw	17 points
6/6/19	QLD	Dedicated Acoustics	External Deck over Habitable		Acoustibond	10 mm Tile	200 mm	100 mm	65 LnTw	56 LnTw	9 points
6/6/19	QLD	Dedicated Acoustics	External Deck Beyond Habitable		Monoflex	10 mm Tile	200 mm	100 mm	66 LnTw	65 LnTw	1 points
7/11/01	WA	Gabriels Environmental	King Street Apartments	5 mm Acoustiflor		10 mm Timber pinned	170 mm	Nil	61 LnTw	49 LnTw	12 points

7/11/01	WA	Gabriels Environmental	King Street Apartments	5 mm Acoustiflor		10 mm Timber no pins	170 mm	Nil	61 LnTw	51 LnTw	10 points
7/11/01	WA	Gabriels Environmental	King Street Apartments	5 mm Acoustiflor	Kemflex	8 mm Tile	170 mm	Nil	61 LnTw	46 LnTw	15 points
11/2/01	WA	Gabriels Environmental	Upper Eastside Apartments	5 mm Acoustiflor	Kemflex	6 mm Tile	200 mm Delta+70 bed	200 cavity	59 LnTw	46 LnTw	13 points
11/2/01	WA	Gabriels Environmental	Upper Eastside Apartments	5 mm Acoustiflor			200 mm Delta+70 bed	200 cavity	59 LnTw	41 LnTw	18 points
11/2/01	WA	Gabriels Environmental	Upper Eastside Apartments	5 mm Acoustiflor	Ultrathane	10 Timber Strip	200 mm Delta+70 bed	200 cavity	59 LnTw	47 LnTw	12 points
11/2/01	WA	Gabriels Environmental	Panorama Apartments	5 mm Acoustiflor			200 mm 100 topping	300 cavity	65 LnTw	44 LnTw	20 points
11/2/01	WA	Gabriels Environmental	Panorama Apartments	5 mm Acoustiflor	Acoustibond	8 mm Tile	200 mm 100 topping	300 cavity	65 LnTw	56 LnTw	9 points
11/2/01	WA	Gabriels Environmental	Panorama Apartments	5 mm Acoustiflor		Parquetry Timber	200 mm 100 topping	300 cavity	65 LnTw	53 LnTw	12 points
11/2/01	WA	Gabriels Environmental	Panorama Apartments	5 mm Acoustiflor	Acoustibond	8 mm Tile	200 mm 100 topping	300 cavity	58 LnTw	49 LnTw	9 points
11/2/01	WA	Gabriels Environmental	Panorama Apartments	5 mm Acoustiflor		Parquetry Timber	200 mm 100 topping	300 cavity	58 LnTw	49 LnTw	9 points
1/25/02	WA	Gabriels Environmental	The Moorings		Kemflex	8 mm Tile	172 mm	100 Cavity	69 LnTw	60 LnTw	9 points
1/25/02	WA	Gabriels Environmental	The Moorings	5 mm Acoustiflor	Kemflex	8 mm Tile	172 mm	100 cavity	69 LnTw	56 LnTw	13 points
1/25/02	WA	Gabriels Environmental	The Moorings		Acoustibond	8 mm Tile	172 mm	100 cavity	69 LnTw	59 LnTw	10 points
1/25/02	WA	Gabriels Environmental	The Moorings	5 mm Acoustiflor	Acoustibond	8 mm Tile	172 mm	100 cavity	69 LnTw	55 LnTw	14 points
1/25/02	WA	Gabriels Environmental	The Moorings	1.5 mm Kemscreed	Acoustibond	8 mm Tile	172 mm	100 cavity	69 LnTw	58 LnTw	11 points
1/25/02	WA	Gabriels Environmental	The Moorings	5 mm Acoustiflor	Urethane	12 mm Jarrah	172 mm	100 cavity	69 LnTw	55 LnTw	14 points
3/8/04	WA	Gabriels Environmental	Delhi Apartments		Acoustibond	8 mm Tile	60mm Form + 112 bed	Nil	65 LnTw	62 LnTw	3 points
3/8/04	WA	Gabriels Environmental	Delhi Apartments	5 mm Acoustiflor	Acoustibond	8 mm Tile	60mm Form + 112 bed	Nil	65 LnTw	56 LnTw	9 points
3/8/04	WA	Gabriels Environmental	Delhi Apartments	5 mm Acoustiflor	Monoflex	8 mm Tile	60mm Form + 112 bed	Nil	65 LnTw	57 LnTw	8 points
3/8/04	WA	Gabriels Environmental	Delhi Apartments		8 mm Acoustibnd	8 mm Tile	60mm Form + 112 bed	Nil	65 LnTw	56 LnTw	9 points
3/8/04	WA	Gabriels Environmental	Hammersley St Apartments	5 mm Acoustiflor	Ultrathane Adhesive	19 mm Blackbutt	172 mm	100 cavity	71 LnTw	58 LnTw	13 points
3/2/05	WA	Gabriels Environmental	Rivervale		Acoustibond	10 mm Tile	175 mm	Nil	71 LnTw	62 LnTw	9 points
3/2/05	WA	Gabriels Environmental	Rivervale	5 mm Acoustiflor	Acoustibond	10 mm Tile	175 mm	Nil	71 LnTw	59 LnTw	12 points
3/2/05	WA	Gabriels Environmental	Rivervale	5 mm Acoustiflor	Acoustibond	10 mm Tile	175 mm	Nil	71 LnTw	62 LnTw	9 points
8/23/06	WA	Gabriels Environmental	Adelaide Tce Perth		Acoustibond	10 mm Tile	200 mm	Nil	70 LnTw	61 LnTw	9 points
8/23/06	WA	Gabriels Environmental	Adelaide Tce Perth	5 mm Acoustiflor	Acoustibond	10 mm Tile	200 mm	Nil	70 LnTw	61 LnTw	9 points
8/23/06	WA	Gabriels Environmental	Stone Street	5 mm Acoustiflor	Acoustibond	10 mm Tile	172 mm	Nil	70 LnTw	58 LnTw	12 points
8/23/06	WA	Gabriels Environmental	Stone Street	5 mm Acoustiflor	Monoflex	10 mm Tile	172 mm	Nil	70 LnTw	54 LnTw	16 points
2/5/07	WA	Gabriels Environmental	Soho Apartments	5 mm Acoustiflor	Dryfast	23 mm plank	280 mm	Nil	70 LnTw	59 LnTw	11 points
2/5/07	WA	Gabriels Environmental	Soho Apartments	5 mm Acoustiflor	Ultrathane	23 mm plank	280 mm	Nil	70 LnTw	57 LnTw	13 points
2/5/07	WA	Gabriels Environmental	Soho Apartments	5 mm Acoustiflor	Acoustibond	10 mm Tile	280 mm	Nil	70 LnTw	55 LnTw	15 points
2/16/07	WA	Gabriels Environmental	Hammersley St Apartments	5 mm Acoustiflor	Holdfast Adhesive	19 mm Blackbutt	172 mm	100 cavity	71 LnTw	60 LnTw	11 points
11/15/07	WA	Gabriels Environmental	Ceressa Apartments	5 mm Acoustiflor	Acoustibond	12 mm Trav Marble	200 mm	Nil	67 LnTw	58 LnTw	9 points
11/15/07	WA	Gabriels Environmental	Ceressa Apartments	5 mm Acoustiflor	Acoustibond	6 mm Tile	200 mm	Nil	67 LnTw	55 LnTw	12 poits
11/15/07	WA	Gabriels Environmental	Ceressa Apartments	5 mm Acoustiflor	Monoflex	6 mm Tile	200 mm	Nil	67 LnTw	56 LnTw	11 points
11/15/07	WA	Gabriels Environmental	Ceressa Apartments	5 mm Acoustiflor	Acoustibond	6 mm Tile	200 mm	Nil	67 LnTw	56 LnTw	11 points
11/15/07	WA	Gabriels Environmental	Ceressa Apartments		Acoustibond	6 mm Tile	200 mm	Nil	67 LnTw	60 LnTw	7 points
4/29/09	WA	Gabriels Environmental	Newcastle Street								
1/28/10	WA	Gabriels Environmental	Armagh Street Perth	6 mm Acoustiflor	Monoflex	9 mm Tile	280 mm	Nil	64 LnTw	49 LnTw	15 points
1/28/10	WA	Gabriels Environmental	Armagh Street Perth	6 mm Acoustiflor	Ultrathane	12 mm Timber	280 mm	Nil	64 LnTw	47 LnTw	17 points
1/28/10	WA	Gabriels Environmental	Armagh Street Perth	6 mm Acoustiflor			280 mm	Nil	64 LnTw	40 LnTw	24 points
1/28/10	WA	Gabriels Environmental	Armagh Street Perth	6 mm Acoustiflor	Foam Grip	12 mm Timber	280 mm	Nil	64 LnTw	49 LnTw	15 points
12/18/00	NZ	HegleyAcoustics	The Atrium	5 mm Acoustiflor	Kemflex	8 mm Tile	125 mm + 80 topping	175 cavity		54 LnTw	
12/18/00	NZ	HegleyAcoustics	The Atrium	5 mm Acoustiflor	Kemflex	8 mm Tile	200 mm + 80 topping	175 cavity		51 LnTw	

12/18/00	NZ	HegleyAcoustics	The Atrium	5 mm Acoustiflor	Kemflex	8 mm Tile	200 mm + 80 topping	175 cavity		50 LnTw	
1/21/02	NZ	Marshall Day	707 Remuer Rd	5 mm Acoustiflor	Kemflex	10 mm Tile	75 mm + 75 topping	cavity	39 FIIC	53 FIIC	14 points
1/21/02	NZ	Marshall Day	707 Remuer Rd	5 mm Acoustiflor	Ultrathane	13 mm Timber	75 mm + 75 topping	cavity	39 FIIC	58 FIIC	19 points
07/03 2003	VIC	Marshall Day	Yarra's Edge	5 mm Acoustiflor	Acoustibond	8 mm Tile	180 mm	300 cavity	43 FIIC	54 FIIC	11 points
9/10/01	SA	Vipac Engineers	Brewery Apartments	5 mm Acoustiflor		12 mm Timber	180 mm	350 cavity	41 FIIC	55 FIIC	14 points
9/10/01	SA	Vipac Engineers	Brewery Apartments	7 mm Acoustiflor		10 mm Tile	180 mm	350 cavity	41 FIIC	54 FIIC	13 points
6/4/07	SA	Vipac Engineers	Newport Quays	5 mm Acoustiflor	Acoustibond	8 mm Tile	200 mm	100 cavity+insul	64 LnTw	52 LnTw	12 points
6/4/07	SA	Vipac Engineers	Newport Quays		Acoustibond	8 mm Tile	200 mm	100 cavity+insul	64 LnTw	58 LnTw	6 points
6/4/07	SA	Vipac Engineers	Newport Quays		Acoustibond (New)	8 mm Tile	200 mm	100 cavity+insul	64 LnTw	57 LnTw	7 points
6/10/08	SA	Vipac Engineers	Newport Quays Stage II	5 mm Acoustiflor	Ultrathane	15 m Bamboo	200 mm	150 cavity	68 LnTw	44 LnTw	24 points
6/10/08	SA	Vipac Engineers	Newport Quays Stage II	5 mm Acoustiflor	Monoflex	8 mm Tile	200 mm	150 cavity	68 LnTw	48 LnTw	20 points
6/10/08	SA	Vipac Engineers	Newport Quays Stage II		Acoustibond	8 mm Tile	200 mm	150 cavity	68 LnTw	56 LnTw	12 points
5/4/09	SA	Vipac Engineers	Infintiy Apartments	5 mm Acoustiflor	Ultrathane	12 mm Bamboo	300 mm	100 cavity	49 FIIC	65 FIIC	16 points
5/4/09	SA	Vipac Engineers	Infintiy Apartments	5 mm Acoustiflor	Acoustibond	10 mm tile	300 mm	100 cavity	49 FIIC	65 FIIC	16 points
5/4/09	SA	Vipac Engineers	Infintiy Apartments		Acoustibond	10 mm Tile	300 mm	100 cavity	49 FIIC	61 FIIC	12 points
30.6.2005	K/L	Palmer Acoustics	Mont Kiara Damai	5 mm Acoustiflor	Acoustibond	10 mm Tile	200 mm	300 caviity	66 LnTw	57 LnTw	9 points