

VOC Content Test Certificate

Monday April 4th, 2011

Manufacturer: Construction Chemicals Pty Ltd (135-147 Cormack Rd, Wingfield, SA)

Sample Description: Flexible Sealer

Date Tested: March 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168

Test Data:

| | |
|---|---|
| Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13 | Flexible Sealer |
| Architectural sealants 250 grams per Litre as VOC content material | 22 grams per Litre as VOC content per material |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1103-17